

SOLICITATION NUMBER: Bid # 17 - 148 – Chiller, Cross Lanes Elementary

Date: May 16, 2017

Addendum Number: [2]

The purpose of this addendum is to modify the solicitation identified as Bid # 17 - 148 – Chiller, Cross Lanes Elementary. (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product in Exhibit B of Bid # 17 – 148 – Chiller, Cross Lanes Elementary
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other – Modifications

Description of Modification to Solicitation:

Please Note to all prospective Vendors the Modification of Specifications of product in Exhibit B, item # 3 of Bid # 17 – 148 – Chiller, Cross Lanes Elementary. The width for the RTU has been changed to a maximum of (55 inches) for item # 3. The base of the RTU must set on the steel support that is on the roof. See Attachment A.

If you have any questions concerning Addendum # 2, please notify me at (304)348-6137. Thanks for your cooperation in this matter.



Ron Ellis, Buyer
Purchasing Department
Kanawha County Schools
3300 Pennsylvania Ave.
Charleston, WV 25302
Email: rlellis@mail.kana.k12.wv.us
Phone: (304)348-6137
Fax: (304)348-6112

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

(Revision and Replacement) of Exhibit B (Bid 17 -148) – Specifications

(See item # 3)

RTU – Chiller (York) equal or equivalent will be accepted**Physical Data and Nominal Ratings (60HZ)**

1. Model – YCAL00 – York	28
2. Length	118.6 – in., maximum
3. Width – Base of RTU must set on the Steel Support on the Roof that is already in place.	55 – in., maximum
4. Height	72”, maximum
5. Nominal Tons	24.3, minimum
6. Number of Refrigerant Circuits	1, minimum
7. Refrig. Chg, Opt, R-410A(lbs)ckt1/ckt2	45, minimum
8. Oil Charge, gallons ckt1/ckt2	1.7, minimum
9. Shipping Weight – Alum.Fin Coils, lbs.	1799, minimum
“ “ - Copper Fin. Coils, lbs.	2005, minimum
10. Operating Weight – Alum. Fin. Coils lbs.	1829, minimum
“ “ - Copper Fin. Coils lbs.	2035, minimum
NOMINAL COMPRESSOR CAPACITY	
11. Compressor 1	15, minimum
12. Compressor 2	13, minimum
13. Compressor 3	-----
14. Compressor 4	-----
15. Compressor 5	-----
16. Compressor 6	-----
17. Condenser – Total Face Area ft^2	43.5, minimum
18. Number of Rows Deep - Ckt. 1	3, minimum
“ “ “ - Ckt. 2	-----
19. Fins per inch	13, minimum
CONDENSER FANS, LOW SOUND	
20. Number of Fans --- Ckt. 1	2, minimum
“ “ --- Ckt. 2	-----
21. Fan Power hp/fan	1.2, minimum
22. Fan RPM	950, minimum
23. Total Chiller CFM	20,000, minimum
CONDENSER FANS, ULTRA QUIET	
24. Number of Fans ----- Ckt. 1	2, minimum
“ “ ----- Ckt. 2	-----
25. Fan Power hp/fan	1.2, minimum
26. Fan RPM	698, minimum
27. Total Chiller CFM	20,000, minimum
EVAPORATOR	
28. Water Volume Gallons	2.5, minimum
29. Max. Water Side Pressure PSIG	300
30. Max. Refrig. Side Pressure PSIG	450
31. Min. Chiller Water Flow GPM	10
32. Max. Chiller Water Flow GPM	150
33. Water Connection Size inches	2, maximum
34. VOLTAGE CODE	- 17
35. UNIT POWER	200-3-60, maximum

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: Bid # 17 - 148 – Chiller, Cross Lanes Elementary

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor’s representatives and any County personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.